



Certificate of Compliance

Certificate: 1167442 (LR 44787-3)

Master Contract: 151908

Project: 2341451

Date Issued: December 14, 2011

Issued to: Kenco Engineering Company

Post Office Drawer 470426

Tulsa, OK 74147

USA

Attention: Darrell Miller

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



D. Simpson Certifier

Issued by: D. Simpson Certifier

PRODUCTS

CLASS 3218 86 - INDUSTRIAL CONTROL EQUIPMENT-Miscellaneous Apparatus - For Hazardous Locations-Certified to U.S. Standards

CLASS 3218 06 - INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous Apparatus - For Hazardous Locations

Class I, Groups B, C and D:

Oil level controllers/switches, Models KLCE, KLCE-DPDT, KES, KES-DPDT, KHL, KHL-ES, KHL-DPDT, KHL-ES-DPDT, KSHL, KSHL-ES, KSSL and KSSL-ES, rated 15A, 125/250/480V ac; 0.5A, 125V dc; 0.25A, 250V dc; 1/8 hp, 125V ac; 1/4 hp, 250V ac; Tamb: -35 Deg. C to +85 Deg. C; Temperature Code T5.

Note: Suffixes may be added to the model designation, denoting mounting holes and/or oil port configurations in the fluid chamber housings, which will not affect the explosion-proof requirements.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 0-M91 - General Requirements – Canadian Electrical Code, Part II

C22.2 No. 14-05 - Industrial Control Equipment



Certificate: 1167442 (LR 44787-3)

Master Contract: 151908

Project: 2341451

Date Issued: December 14, 2011

C22.2 No. 30-M1986 - Explosion-Proof Enclosures for Use in Class I Hazardous Locations

UL 508 (17th Ed) - Industrial Control Equipment

UL 1203 (4th Ed.) - Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations